




Door Closer



Technical Data:

Operating Voltage	24V DC + or - 15%
Power Input	1.4W
Rated for continuous duty	100%

41004 electromagnetic hold open door closer

- Door closer will hold the door open between 75 & 180 degrees and automatically close upon activation of fire alarm system or power failure
- Standard unit suitable for doors up to 1100mm. For doors up to 1250mm suffix '5' and for doors up to 1400mm suffix '6' (ie 410045 or 410046)
- 24V operating voltage
- Available in satin or polished stainless steel & silver enamel with matching arm

Technical Data

Fire Test Certificate:
Certifire approved

Certification:
Tested to EN1154 Classification 4.8.4/4.1.1.3

Maintenance

To be carried out by approved specialists only.
A door stop must be fitted to limit the opening of the door. Regularly check the assembly for tolerance and undue wear. Tighten any screws or bolts that may become loose and adjust the closer if necessary. Annually grease the moving parts and check the operation of the doors adjusting if necessary. Repair works or any replacements have to be executed by the manufacturer or specialists authorised by the manufacturer.
If for any reason the products fail due to a defect in manufacture, contact us and we will advise you of the replacement procedure.