

Test report summary issued to:

Aspex UK Ltd

Unit E Winchester Avenue
Blaby
Leicester
LE8 4GZ

Timber Novista Riser Double Leaf Doorset


Doorset as specified in TR1853 has successfully: **PASSED**
When tested in accordance with:

Test type - BS6375-1 (TR1853/C1)	Test Pressure (Pa) & Test Class
Air permeability	300 Pa / Class 2
Average air classification for overall area	Class Three
Average air classification for joint length	Class Two


Test type - BSEN1634-3 (TR1853/F1)		Tested in the closed and latched condition			
Pressure direction	Temperature	Total leakage rate (AREA) Q _{spec} (°) (m³/h)		Linear leakage rate (OPENING JOINT) Q _l (m³/h/m)	
		10Pa	25Pa	10Pa	25Pa
Positive result	Ambient	1.2	2.3	0.8	0.9
Negative result	Ambient	1.2	2.1	0.7	1.2
Smoke control classification (BS EN13501-2: 2016)		S _a			

This test result summary is only valid when read in conjunction with test report: TR1853.

Drafted on behalf of Winkhaus Laboratories:

 02-07-2019.
Mr. Ade Collins Laboratory Manager.

Authorised on behalf of Winkhaus Laboratories:

 02/07/2019.
Mr. Ross Howitt-Page Senior Laboratory Technician.

This test result summary shall not be reproduced except in full, without the written authority of Winkhaus Laboratory.

ISSUE 1	02 / 07 / 2019	Original copy
---------	----------------	---------------

Page 1 of 1