

## Test report summary issued to:

# Aspex UK Ltd

Unit E Winchester Avenue  
Blaby  
Leicester  
LE8 4GZ

### Steel Novista Riser Double Leaf Doorset

Doorset as specified in TR1854 has successfully: **PASSED**  
When tested in accordance with:

Test type - BS6375-1 (TR1854/C1)	Test Pressure (Pa) & Test Class
Air permeability	300 Pa / Class 2
Average air classification for overall area	Class Two
Average air classification for joint length	Class Two

Test type - BSEN1634-3 (TR1854/F1)		Tested in the closed and locked condition			
Pressure direction	Temperature	Total leakage rate (AREA) Q <sub>spec</sub> (°) (m³/h)		Linear leakage rate (OPENING JOINT) Q <sub>l</sub> (m³/h/m)	
		10Pa	25Pa	10Pa	25Pa
Positive result	Ambient	4.0	7.1	1.6	2.8
Negative result	Ambient	3.9	7.0	2.2	3.9
Smoke control classification (BS EN13501-2: 2016)		Sa			

This test result summary is only valid when read in conjunction with test report: TR1854.

Drafted on behalf of Winkhaus Laboratories:

*[Signature]* 02-07-2019.  
Mr. Ade Collins Laboratory Manager.

Authorised on behalf of Winkhaus Laboratories:

*[Signature]* 02/07/2019.  
Mr. Ross Howitt-Page Senior Laboratory Technician.

This test result summary shall not be reproduced except in full, without the written authority of Winkhaus Laboratory.

ISSUE 1	02 / 07 / 2019	Original copy
---------	----------------	---------------

Page 1 of 1

